

Fire Protection Systems Inspection, Testing, and Maintenance Schedules

Emergency/Exit Lighting Testing and Inspection Schedule

NFPA 101 (*Life Safety Code*) set standards to ensure proper exit sign and emergency lighting placement, visibility, and performance in various settings.

- **Monthly:** Visual 30 second inspection. This can be done by the property owner by pressing the 'test' button on the unit.
- Annually: 90-minute load testing by qualified person.
- Emergency back-up batteries shall be replaced at intervals set by the manufacturer, or when light fails to continually illuminate for the full 90-minutes.



Your facility may have additional systems in need of certification by a fire protection company. Discuss your needs with your fire protection contractor or contact Canby Fire District for more information.

To gain additional information, or for questions, please contact our Fire Inspector at: (503) 263-4281.